

| Pulaski Academy & Central School District | | | | |
|---|--|-------------------------|---|--|
| lead level in parts per billion (actionable level 15ppb) | | | | |
| | | | | |
| Location of Sample | May 24, 2021 Sample Results | Remediation Plan | July 19, 2021 Sample Results | October 17, 2021 Sample Results |
| Elementary School Kitchen sanitizing sink (room 27-7) | 114 | replaced faucet | 6.1 | NA |
| Elementary School Kitchen sanitizing sink (room 27-8) | 326 | replaced faucet | <1 | NA |
| Elementary School CITI BOCES hallway bathroom sink (room 18-2) | 25.6 | replaced faucet | 3.2 | NA |
| Elementary School CITI BOCES hallway bathroom sink (room 19-1) | 17 | replaced faucet | 9.9 | NA |
| Elementary School School-Based Health Center office sink (room 127-1) | 476 | installed filter | 1 | NA |
| Elementary School School-Based Health Center office sink (room 127-4) | 57.3 | installed filter | 10.7 | NA |
| High School classroom sink (room 206) | 28.3 | removed | NA | NA |
| Middle School locker room sink (room 140-2) | 184 | replaced faucet | 21.8 | <1 |
| | | | | |
| *Analysis conducted by Pace Analytical Laboratories | | | | |